

KERALA UNIVERSITY OF HEALTH SCIENCES
Medical College (PO), THRISSUR – 680 596

Quotation Format

Name of Work: Supply of 3 Nos of ELCB (300mA 4 pole RCBO) at KUHS Thrissur.

Ref: Quotation Notice No. 136/2026/14/WORKS/KUHS dated 08-10-2026

PRICE SCHEDULE

Sl No.	Item	Unit	Qty	Rate(₹)	Rate in words	Amount(₹)
1.	63A, 4 Pole, 300mA RCBO specification: 63A, 4 Pole RCBO, 415V AC, 50Hz, 300mA Earth Leakage Protection, C-Curve, 10kA Breaking Capacity, DIN Rail Mounting, with Overload, Short Circuit and Residual Current Protection,3-Phase + Neutral system. 4 Pole RCBO – 300 mA Type: RCBO (RCCB + MCB) Poles: 4 Pole (3P+N) Rated Current: As required (63A) Rated Voltage: 415 V AC Frequency: 50 Hz Residual Current (IΔn): 300 mA Trip Characteristics: C Curve Mounting: DIN Rail Suitable for: Overload, Short Circuit & Earth Leakage Protection Make :- Legrand	Nos	3			
	Total Estimation PAC					
	GST 18.00%					
	Grand Total					
	Amount in words:					

Signature of the quotationer

The work will be executed as per the item specification and terms and conditions stipulated in the quotation notice. The work will be completed within one month of placement of the work order. The payment terms are also accepted.

Place: Signature, Name & Address of the quotationer

Date:

Digitally signed by
Bijesh P
Date: 08-10-2026
10:23:36